






NOTES:
600 Ø 100D - ID = 585mm
- OD = 699mm

NOTES:
SPIDER CARRIER IS TO BE SO MANUFACTURED THAT WITH THE NYLON SKIDS FITTED THERE IN 25mm SPACE BETWEEN THE CARRIER PIPE & TWO LEGS OF THE 'SPIDER'



- NOTES:
1. STEEL "SPIDERS" SHALL BE USED FOR SUPPORT OF THE CARRIER PIPE WITHIN THE CASING PIPE.
 2. A MIN. SPACING OF 4 SPIDERS PER 12m LENGTH OF PIPE SHALL BE REQUIRED. MAXIMUM OF 3m C/C
 3. THE SPIDERS SHALL BE SPACED EVENLY ALONG THE CARRIER PIPE SUCH THAT EACH SPIDER SUPPORTS THE SAME UNIT WEIGHT OF THE CARRIER MAIN.
 4. 600mm CONCRETE ENCASEMENT PIPE & ALL SPIDERS TO BE HOT DIPPED GALVANIZED.



The design and content of this drawing is the property of Osmond Lange Architects and the copyright thereof is reserved by them.

- GENERAL NOTE
1. ALL STRUCTURAL, ELECTRICAL, CIVIL AND LANDSCAPING QUERIES ARE TO BE REFERRED TO THE RELEVANT CONSULTANTS DRAWINGS, SPECIFICATIONS AND DETAILS
 2. ALL PLUMBING QUERIES ARE TO BE REFERRED TO THE RELEVANT SPECIALIST CONSULTANTS DRAWINGS, SPECIFICATIONS AND DETAILS
 3. ALL CONCRETE, COLUMNS AND STRUCTURAL QUERIES ARE TO BE REFERRED TO THE STRUCTURAL ENGINEER'S DRAWINGS, SPECIFICATIONS AND DETAILS
 4. ALL EXTERNAL / INTERNAL WALLS REQUIRING BRACING / STIFFENING ARE TO BE CONSTRUCTED IN ACCORDANCE WITH THE STRUCTURAL ENGINEER'S DRAWINGS, SPECIFICATIONS AND DETAILS
 5. ALL SPECIFICATIONS REGARDING TO PIPE REGULATIONS, TO BE REFERRED TO CONSULTANTS DRAWINGS, SPECIFICATIONS AND DETAILS
 6. ALL DESIGN AND CONSTRUCTION TO COMPLY WITH THE RELEVANT SANS REGULATIONS
 7. ANY DISCREPANCY IN THE DRAWINGS, DIMENSIONS & SPECIFICATIONS TO BE BROUGHT TO THE ATTENTION OF THE CONSULTANT AND ARCHITECT PRIOR TO ANY WORK BEING PUT IN HAND.
 8. ONLY FIGURED DIMENSIONS TO BE FOLLOWED - SCALED DIMENSIONS OF DRAWINGS WILL NOT BE PERMITTED

| No | Date | Revision Description | By |
|----|------|----------------------|----|
| | | | |

PROJECT TEAM

Project Managers :
newground projects
Newground Projects 17 St Andrews Road, Selborne, East London, 5201 043 722 5964
Louis Fourie 0825769828
Louis@newground.co.za

Principal Agent/ Architects :
OL
Osmond Lange Architects and Planners Pilot Mill House, The Quarry, Selborne East London 043) 721-0033
William Martinson 083 3259600
Williamm@ol.co.za

Quantity Surveyors :
BVNI
Bliswe Van Niekerk The Ridge Office Park, 2nd Floor 3 Berea Terrace, Berea, East London 043 721 1043
Willem van Niekerk 0824921695
willem@blisive.co.za

Civil & Structural Engineers
bvni
BVI Border 1st Floor, Esprit House, St Helena Drive East London, 5241 043 - 722 2738
Werner de Lange 082 578 0674
WernerDL@bvni.co.za

Electrical & Mechanical Engineers :
evans
Evans Consulting Engineers cc 17 Surrey Road, Vincent, East London 5247 043 7213192
Darryl Evans 083 7026399
darryl@evansconsulting.co.za

Town Planners :
CS CONSULTING
CS Consulting 12 Pearce Street, Harraway House Berea, East London 5241
Craig Sam 0793267147
Craig@csamconsulting.co.za

CLEINT

east london idz
PO Box 5458, Greenfields East London, 5208
Lower Chetler Road Sunningdale, 5201 East London, South Africa
Tel: +27(0)437028200 Fax: +27(0)437366405 Email: info@elidz.co.za

CLIENT APPROVAL :
Gary Whittaker Project Manager Tel: 043 7026247 Cell: 082 34832299 Email: gary@elidz.co.za

DATE :

TENANT

NAME :
TENANT APPROVAL :
DESIGNATION :
DATE :

Project
ELIDZ- ASP2 - HW1

Drawing Title
FIRE WATER SUPPLY SLEEVED PIPE DETAILS

Date 01.05.2019 Drawn Author
Scale AS SHOWN Checked Checker

Approved
Name: Approver Reg No: PrArch5559
Signature: Date:
Practice: Osmond Lange Architects and Planners

Workstage
FOR INFORMATION

Drawing Number
33722-HW1 ·DET-15

Revision
2019/05/06 12:02:01 PM