


- LEGEND:**
- 75mm Ø CLASS 9 PVCu DOMESTIC WATER MAIN BSC
 - 75mm Ø PVC FLANGE ADAPTOR
 - 80 Ø x 430mm G.I DOMESTIC WATER EXTENTION PIECE ONE END PLAIN ONE END BUTTWELDED TO BEND
 - WRAPID BOND WRAPPING OF ALL UNDERGROUND STEEL PIPES & FITTING
 - 80mm Ø G.I PUDDLE FLANGE
 - 80mm Ø 90° G.I BUTTWELDED LONG RADIUS BEND
 - 80 Ø x 1036mm G.I EXTENTION PIECE ONE END PLAIN OTHER END BUTTWELDED TO BEND
 - CONCRETE ENCASEMENT 25/19MPa


NOTE: ALL FLANGES TO BE T10



**75mm Ø DOMESTIC WATER
BSC 1 INSTALLATION**
SCALE 1:20

- LEGEND:**
- 100mm Ø CLASS 12 PVCu FIRE MAIN BSC
 - 100mm Ø PVC FLANGE ADAPTOR
 - 100 Ø x 500mm G.I FIRE SPRINKLER EXTENTION PIECE ONE END PLAIN OTHER BUTTWELDED TO BEND
 - 100mm Ø G.I PUDDLE FLANGE
 - WRAPID BOND WRAPPING OF ALL UNDERGROUND STEEL PIPES & FITTING
 - 100mm Ø 90° G.I BUTTWELDED LONG RADIUS BEND
 - 100 Ø x 1928mm G.I FIRE SPRINKLER EXTENTION PIECE ONE END PLAIN OTHER END BUTTWELDED TO BEND
 - CONCRETE ENCASEMENT 25/19MPa


NOTE: ALL FLANGES TO BE T16



**SOUTH EAST: 100mm Ø G.I
FIRE BSC 2 INSTALLATION**
SCALE 1:20

- LEGEND:**
- 32mm Ø CLASS 10 HDPE DOMESTIC WATER MAIN BSC
 - 32mm Ø PVC FLANGE ADAPTOR
 - 32 Ø x 500mm G.I DOMESTIC WATER EXTENTION PIECE ONE END PLAIN ONE END BUTTWELDED TO BEND
 - WRAPID BOND WRAPPING OF ALL UNDERGROUND STEEL PIPES & FITTING
 - 32mm Ø G.I PUDDLE FLANGE
 - 32mm Ø 90° G.I BUTTWELDED LONG RADIUS BEND
 - 32 Ø x 1601mm G.I EXTENTION PIECE ONE END PLAIN OTHER END BUTTWELDED TO BEND
 - CONCRETE ENCASEMENT 25/19MPa


NOTE: ALL FLANGES TO BE T10



**NORTH EAST: 32mm Ø DOMESTIC
WATER BSC 1 INSTALLATION**
SCALE 1:20

- LEGEND:**
- 100mm Ø CLASS 12 PVCu FIRE MAIN BSC
 - 100mm Ø PVC FLANGE ADAPTOR
 - 100 Ø x 500mm G.I FIRE SPRINKLER EXTENTION PIECE ONE END PLAIN OTHER BUTTWELDED TO BEND
 - 100mm Ø G.I PUDDLE FLANGE
 - WRAPID BOND WRAPPING OF ALL UNDERGROUND STEEL PIPES & FITTING
 - 10mm Ø 90° G.I BUTTWELDED LONG RADIUS BEND
 - 100 Ø x 1458mm G.I FIRE SPRINKLER EXTENTION PIECE ONE END PLAIN OTHER BUTTWELDED TO BEND
 - CONCRETE ENCASEMENT 25/19MPa

NOTE: ALL FLANGES TO BE T16




**NORTH EAST: 100mm Ø G.I
FIRE BSC 2 INSTALLATION**
SCALE 1:20

LEGEND:

- 32mm Ø CLASS 10 HDPE DOMESTIC WATER MAIN BSC
- 32mm Ø PVC FLANGE ADAPTOR
- 32 Ø x 500mm G.I DOMESTIC WATER EXTENTION PIECE ONE END PLAIN ONE END BUTTWELDED TO BEND
- WRAPID BOND WRAPPING OF ALL UNDERGROUND STEEL PIPES & FITTING
- 32mm Ø G.I PUDDLE FLANGE
- 32mm Ø 90° G.I BUTTWELDED LONG RADIUS BEND
- 32 Ø x 2152mm G.I EXTENTION PIECE ONE END PLAIN OTHER END BUTTWELDED TO BEND
- CONCRETE ENCASEMENT 25/19MPa


NOTE: ALL FLANGES TO BE T10



**SOUTH EAST: 32mm Ø DOMESTIC
WATER BSC 1 INSTALLATION**
SCALE 1:20

- LEGEND:**
- 250mm Ø CLASS 20 PVCu FIRE SPRINKLER MAIN BSC
 - 250mm Ø PVC FLANGE ADAPTOR
 - 250 Ø x 500mm G.I FIRE SPRINKLER EXTENTION PIECE ONE END PLAIN OTHER END BUTTWELDED TO BEND
 - 250mm Ø G.I PUDDLE FLANGE
 - WRAPID BOND WRAPPING OF ALL UNDERGROUND STEEL PIPES & FITTING
 - 250mm Ø 90° G.I BUTTWELDED LONG RADIUS BEND
 - 10mm DUCK FOOT PLATE SUPPORT
 - 250 Ø x 1189mm G.I FIRE SPRINKLER EXTENTION PIECE ONE END PLAIN OTHER END BUTTWELDED TO BEND
 - CONCRETE ENCASEMENT 25/19MPa

NOTE: ALL FLANGES TO BE T25



**250mm Ø G.I FIRE SPRINKLER
BCS 3 INSTALLATION**
SCALE 1:20

Osmond Lange Architects and Planners (Pty) Ltd East London

Postal: P O Box 19175, Tecom, 5214

Address: Pilot Mill House The Quarry Selborne, East London

Tel: (043) 721-0033
Fax: (043) 721-0038
Email: en@o-l.co.za

The design and content of this drawing is the property of Osmond Lange Architects and the copyright thereof is reserved by them.

GENERAL NOTE:

1. ALL STRUCTURAL, ELECTRICAL, CIVIL AND LANDSCAPING QUERIES ARE TO BE REFERRED TO THE RELEVANT CONSULTANTS DRAWINGS.
2. ALL PLUMBING QUERIES ARE TO BE REFERRED TO THE RELEVANT SPECIALIST CONSULTANT DRAWINGS, SPECIFICATIONS AND DETAILS.
3. ALL CONCRETE, COLUMN AND STRUCTURAL QUERIES ARE TO BE REFERRED TO THE STRUCTURAL ENGINEER'S DRAWINGS, SPECIFICATIONS AND DETAILS.
4. ALL EXTERNAL INTERNAL WALLS REQUIRING BRACING/STRENGTHENING ARE TO BE CONSTRUCTED IN ACCORDANCE WITH PRE-STRUCTURAL ENGINEER'S DRAWINGS, SPECIFICATIONS AND DETAILS.
5. ALL SPECIFICATIONS WITH REGARD TO FIRE REGULATIONS, TO BE REFERRED TO CONSULTANTS DRAWINGS, SPECIFICATIONS AND DETAILS.
6. ALL DESIGN AND CONSTRUCTION TO COMPLY WITH THE RELEVANT SANS REGULATIONS.
7. ANY DISCREPANCY IN THE DRAWINGS, DIMENSIONS & SPECIFICATIONS TO BE BROUGHT TO THE ATTENTION OF THE CONSULTANT AND ARCHITECT PRIOR TO ANY WORK BEING PUT IN HAND.
8. ONLY FIGURED DIMENSIONS TO BE FOLLOWED - SCALED DIMENSIONS OF DRAWINGS WILL NOT BE PERMITTED

No	Date	Revision Description	By
----	------	----------------------	----

PROJECT TEAM

Project Managers :

newground
projects
Newground Projects 17 St Andrews Road, Selborne, East London, 5201 043 722 5864
Louis Fourie
0825766828
Louis@newground.co.za

Principal Agent/ Architects :

OL
OSMOND LANGE
ARCHITECTS & PLANNERS
Osmond Lange Architects and Planners Pilot Mill House, The Quarry, Selborne East London (043) 721-0033
William Martinson
083 3259600
William@o-l.co.za

Quantity Surveyors :

BISWE VAN NIEKERK
Biswe Van Niekerk The Ridge Office Park, 2nd Floor 3 Berea Terrace, Berea, East London 043 721 1043
Willem van Niekerk
0824921055
willem@biswe.co.za

Civil & Structural Engineers :

bvi
BVI Border 1st Floor, Esprit House, St Helena Drive East London, 5241
043 - 722 2738
Werner de Lange
082 578 0514
Werner@bvi.co.za

Electrical & Mechanical Engineers :

evans
Evans Consulting Engineers cc 17 Surrey Road, Vincent, East London 5247
043 7213192
Darryl Evans 083 7026399
darryl@evansconsulting.co.za

Town Planners :

CS CONSULTING
CS Consulting 12 Pearce Street, Harraway House Berea, East London 5241
Craig Sam
0783267147
Craig@csamconsulting.co.za

CLEINT

east london idz
business streamlined
PO Box 5458, Greenfields East London, 5208
Lower Chester Road Sunningridge, 5201
East London, South Africa
Tel: +27(0)437028200
Fax: +27(0)437366405
Email: info@elidz.co.za

CLIENT APPROVAL :

Cary Whitfield
Project Manager
Tel: 043 7028247
Cell: 082 34632298
E-mail: gary@elidz.co.za

DATE :

TENANT

NAME : _____ TENANT APPROVAL : _____
DESIGNATION : _____ DATE : _____

Project

Drawing Title
**DOMESTIC WATER, FIRE & SPRINKLER
SYSTEM BUILDING SUPPLY
CONNECTION DETAILS**

Date	01.05.2019	Drawn	Author
Scale	AS SHOWN	Checked	Checker

Approved

Name: Approver Reg No: PrArch5559
Signature: _____ Date: _____
Practice: Osmond Lange Architects and Planners

Workstage

FOR INFORMATION

Drawing Number	Revision
33722- HS1 -DET-18	