DESCRIPTION	TYPE
INTERNAL QUALITY - STANDARD 2 HOUR SABS CLASS B FIRE RATED UN-EQUAL LEAF HINGED DOUBLE DOOR 1511 x 2400 x 48mm INCLUDING FRAME SUITABLE FOR 230mm BRICK WALL. SUPPLY AND INSTALL PYROPANEL FIRE RATED DOORSET IN STRICT ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS AND IN COMPLIANCE WITH SABS 1253 : 2003 FOR A 120 MINUTE FIRE RATING WITH 3.6mm TREATED COMMERCIAL PLY SUITABLE FOR PAINTING ON BOTH SIDES, COLOUR: RAL 7016 – ANTHRACITE GREY. INCLUDING INTUMESCENT STRIP TO TOP OF DOOR, HARDWOOD EDGES, SPECIFIED IRONMONGERY AND HINGED ONE SIDE TO SUITABLE 1.6mm GAUGE DOUBLE REBATED GALVANIZED STEEL FRAME.	FD-1

DOOR NO	ROOM DESCRIPTION NAME	NO.	ACTIVE LEAF	HAND	DOOR CONSTRUCTION WIDTH	HEIGHT	GLAZING
17	DATA CENTRE HALL 1	019			1511	2400	N/A
19	DATA CENTRE HALL 2	021			1511	2400	N/A
21	DATA CENTRE HALL 3	024			1511	2400	N/A
26	DATA CENTRE HALL 4	028			1511	2400	N/A
28	CARRIER HOTEL	031			1511	2400	N/A
30	DATA CENTRE HALL 5	033			1511	2400	N/A
39	MEET-ME ROOM 2	040			1511	2400	N/A
41	MEET-ME ROOM 1	042			1511	2400	N/A

IRONMONGERY SET - 02

CLASS B FIRE DOOR
INTERNAL QUALITY
ACCESS CONTROLLED



TYPE FD-1

ELEVATION

DESCRIPTION	TYPE
INTERNAL QUALITY - STANDARD 2 HOUR SABS CLASS B FIRE RATED HINGED SINGLE DOOR 813 x 2400 x 48mm INCLUDING FRAME SUITABLE FOR 230mm BRICK WALL. SUPPLY AND INSTALL PYROPANEL FIRE RATED DOORSET IN STRICT ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS AND IN COMPLIANCE WITH SABS 1253 : 2003 FOR A 120 MINUTE FIRE RATING WITH 3.6mm TREATED COMMERCIAL PLY SUITABLE FOR PAINTING ON BOTH SIDES, COLOUR: RAL 7016 – ANTHRACITE GREY. INCLUDING INTUMESCENT STRIP TO TOP OF DOOR, HARDWOOD EDGES, SPECIFIED IRONMONGERY AND HINGED ONE SIDE TO SUITABLE 1.6mm GAUGE DOUBLE REBATED GALVANIZED STEEL FRAME.	FD-2

DOOR NO	ROOM DESCRIPTION NAME	NO.	ACTIVE LEAF	HAND	DOOR CONSTRUCTION WIDTH	HEIGHT	GLAZING
04	RECEPTION	002			813	2400	N/A
16	DATA CENTRE HALL 1	019			813	2400	N/A
18	DATA CENTRE HALL 2	021			813	2400	N/A
20	DATA CENTRE HALL 3	024			813	2400	N/A
27	CIRCULATION 1	018			813	2400	N/A
29	CIRCULATION 1	018			813	2400	N/A
31	DATA CENTRE HALL 5	033			813	2400	N/A
47	MAINTENANCE STAIR	027			813	2400	N/A
54	FIRE SUPRESSION RM 1	059			813	2400	N/A

IRONMONGERY SET - 03

CLASS B FIRE DOOR
INTERNAL QUALITY
ACCESS CONTROLLED



TYPE FD-2

ELEVATION

DESCRIPTION	TYPE
INTERNAL QUALITY - STANDARD 2 HOUR SABS CLASS B FIRE RATED UN-EQUAL LEAF HINGED DOUBLE DOOR 1511 x 2400 x 48mm INCLUDING FRAME SUITABLE FOR 230mm BRICK WALL. SUPPLY AND INSTALL PYROPANEL FIRE RATED DOORSET IN STRICT ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS AND IN COMPLIANCE WITH SABS 1253 : 2003 FOR A 120 MINUTE FIRE RATING WITH 3.6mm TREATED COMMERCIAL PLY SUITABLE FOR PAINTING ON BOTH SIDES, COLOUR: RAL 7016 – ANTHRACITE GREY. INCLUDING INTUMESCENT STRIP TO TOP OF DOOR, HARDWOOD EDGES, SPECIFIED IRONMONGERY AND HINGED ONE SIDE TO SUITABLE 1.6mm GAUGE DOUBLE REBATED GALVANIZED STEEL FRAME. 100x300mm DOUBLE GLAZED CLEAR GEORGIAN WIRE VIEWING PANEL WITH BRUSHED STAINLESS STEEL FRAME TO EACH LEAF.	FD-3

DOOR NO	ROOM DESCRIPTION NAME	NO.	ACTIVE LEAF	HAND	DOOR CONSTRUCTION WIDTH	HEIGHT	GLAZING
23	SERVICES CORRIDOR 1	023			1511	2400	APPROVED SAFETY GLAZING
25	SERVICES CORRIDOR 2	030			1511	2400	APPROVED SAFETY GLAZING

IRONMONGERY SET
FD3/23 - 02
FD3/25 - 02
FD3/118 - 17

CLASS B FIRE DOOR
INTERNAL QUALITY
ACCESS CONTROLLED



TYPE FD-3

ELEVATION

DESCRIPTION	TYPE
INTERNAL QUALITY - STANDARD 1 HOUR SABS CLASS A FIRE RATED HINGED SINGLE DOOR 813 x 2400 x 48mm INCLUDING FRAME SUITABLE FOR 230mm BRICK WALL. SUPPLY AND INSTALL PYROPANEL FIRE RATED DOORSET IN STRICT ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS AND IN COMPLIANCE WITH SABS 1253 : 2003 FOR A 120 MINUTE FIRE RATING WITH 3.6mm TREATED COMMERCIAL PLY SUITABLE FOR PAINTING ON BOTH SIDES, COLOUR: RAL 7016 – ANTHRACITE GREY. INCLUDING INTUMESCENT STRIP TO TOP OF DOOR, HARDWOOD EDGES, SPECIFIED IRONMONGERY AND HINGED ONE SIDE TO SUITABLE 1.6mm GAUGE DOUBLE REBATED GALVANIZED STEEL FRAME. 100x300mm DOUBLE GLAZED CLEAR GEORGIAN WIRE VIEWING PANEL WITH BRUSHED STAINLESS STEEL FRAME TO EACH LEAF.	FD-5

DOOR NO	ROOM DESCRIPTION NAME	NO.	ACTIVE LEAF	HAND	DOOR CONSTRUCTION WIDTH	HEIGHT	GLAZING
13	ESCAPE STAIR LOBBY	016			813	2400	
14	ESCAPE STAIR LOBBY	016			813	2400	

IRONMONGERY SET - 16

CLASS A FIRE DOOR
INTERNAL QUALITY
PANIC DEVICE



TYPE FD-5

ELEVATION

DESCRIPTION	TYPE
INTERNAL QUALITY - STANDARD 1 HOUR SABS CLASS B FIRE RATED UN-EQUAL LEAF HINGED DOUBLE DOOR 1511 x 2400 x 48mm INCLUDING FRAME SUITABLE FOR 230mm BRICK WALL. SUPPLY AND INSTALL PYROPANEL FIRE RATED DOORSET IN STRICT ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS AND IN COMPLIANCE WITH SABS 1253 : 2003 FOR A 120 MINUTE FIRE RATING WITH 3.6mm TREATED COMMERCIAL PLY SUITABLE FOR PAINTING ON BOTH SIDES, COLOUR: RAL 7016 – ANTHRACITE GREY. INCLUDING INTUMESCENT STRIP TO TOP OF DOOR, HARDWOOD EDGES, SPECIFIED IRONMONGERY AND HINGED ONE SIDE TO SUITABLE 1.6mm GAUGE DOUBLE REBATED GALVANIZED STEEL FRAME. 100x300mm DOUBLE GLAZED CLEAR GEORGIAN WIRE VIEWING PANEL WITH BRUSHED STAINLESS STEEL FRAME TO EACH LEAF.	FD-6

DOOR NO	ROOM DESCRIPTION NAME	NO.	ACTIVE LEAF	HAND	DOOR CONSTRUCTION WIDTH	HEIGHT	GLAZING
110	ACCOUNTS	114			1511	2400	

IRONMONGERY SET - 22

CLASS A FIRE DOOR
INTERNAL QUALITY
PANIC DEVICE



TYPE FD-6

ELEVATION

DESCRIPTION	TYPE
INTERNAL QUALITY - STANDARD 2 HOUR SABS CLASS B FIRE RATED HINGED SINGLE DOOR 813 x 2032 x 48mm INCLUDING FRAME SUITABLE FOR 230mm BRICK WALL. SUPPLY AND INSTALL PYROPANEL FIRE RATED DOORSET IN STRICT ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS AND IN COMPLIANCE WITH SABS 1253 : 2003 FOR A 120 MINUTE FIRE RATING WITH 3.6mm TREATED COMMERCIAL PLY SUITABLE FOR PAINTING ON BOTH SIDES, COLOUR: RAL 7016 – ANTHRACITE GREY. INCLUDING INTUMESCENT STRIP TO TOP OF DOOR, HARDWOOD EDGES, SPECIFIED IRONMONGERY AND HINGED ONE SIDE TO SUITABLE 1.6mm GAUGE DOUBLE REBATED GALVANIZED STEEL FRAME.	FD-8

DOOR NO	ROOM DESCRIPTION NAME	NO.	ACTIVE LEAF	HAND	DOOR CONSTRUCTION WIDTH	HEIGHT	GLAZING
68	ABOVE DATA HALL CEILING	124			813	2032	N/A
69	ABOVE DATA HALL CEILING	124			813	2032	N/A
70	ABOVE DATA HALL CEILING	125			813	2032	N/A
71	ABOVE DATA HALL CEILING	125			813	2032	N/A
72	ABOVE DATA HALL CEILING	125			813	2032	N/A
123	SLAB - TOP OF MAINTENANCE STAIR	123			813	2032	N/A
67	ABOVE DATA HALL CEILING	124			813	2032	N/A
118	SLAB - TOP OF MAINTENANCE STAIR	123			813	2032	N/A

IRONMONGERY SET - 03

CLASS B FIRE DOOR
INTERNAL QUALITY
ACCESS CONTROLLED



TYPE FD-8

ELEVATION

DESCRIPTION	TYPE
HB5 NUKLIP PURPOSE MADE POWDER COATED ALUMINIUM SHOPFRONT SYSTEM BY SPECIALIST.	SF-1

DOOR NO	ROOM DESCRIPTION NAME	NO.	ACTIVE LEAF	HAND	DOOR CONSTRUCTION WIDTH	HEIGHT	GLAZING
01	WIND LOBBY	001			1660	2375	6.38mm CLEAR SAFETY GLASS
02	RECEPTION	002			1660	2375	6.38mm CLEAR SAFETY GLASS

IRONMONGERY SET - 01

ACCESS CONTROLLED



TYPE SF-1

ELEVATION

DESCRIPTION	TYPE
HB5 NUKLIP PURPOSE MADE POWDER COATED ALUMINIUM SHOPFRONT SYSTEM BY SPECIALIST.	SF-2

DOOR NO	ROOM DESCRIPTION NAME	NO.	ACTIVE LEAF	HAND	DOOR CONSTRUCTION WIDTH	HEIGHT	GLAZING
05	CIRCULATION	004			1500	2400	6.38mm CLEAR SAFETY GLASS
22	CORRIDOR LOBBY 1	026			1500	2400	6.38mm CLEAR SAFETY GLASS
32	RECIEVING LOBBY	035			1500	2400	6.38mm CLEAR SAFETY GLASS
33	RECEIVING AREA	036			1500	2400	6.38mm CLEAR SAFETY GLASS
40	STAGING AREA	041			1500	2400	6.38mm CLEAR SAFETY GLASS
109	BALCONY 2	115			1500	2400	6.38mm CLEAR SAFETY GLASS
112	CIRCULATION	101			1500	2400	6.38mm CLEAR SAFETY GLASS
113	EXECUTIVE PAUSE AREA	116			1500	2400	6.38mm CLEAR SAFETY GLASS
116	EXECUTIVE PASSAGE	118			1500	2400	6.38mm CLEAR SAFETY GLASS

IRONMONGERY SET
SF2/05 - 01
SF2/22 - 26
SF2/32 - 01
SF2/33 - 01
SF2/40 - 01
SF2/109 - 01
SF2/112 - 23
SF2/113 - 23
SF2/116 - 23

ACCESS CONTROLLED



TYPE SF-2

ELEVATION

DESCRIPTION	TYPE
HB5 NUKLIP PURPOSE MADE POWDER COATED ALUMINIUM SHOPFRONT SYSTEM BY SPECIALIST, 2400mm WIDE x 2400mm HIGH - HINGED SINGLE DOOR 900mm WIDE x 2400mm HIGH WITH 1500mm WIDE SIDE LIGHT	SF-3

DOOR NO	ROOM DESCRIPTION NAME	NO.	HAND	DOOR CONSTRUCTION WIDTH	HEIGHT	GLAZING
12	NETWORK OPERATIONS	014		2400	2400	6.76 ACOUSTIC CLEAR LAMINATED SAFTEY GLASS
111	MEETING ROOM 2	102		2400	2400	6.76 ACOUSTIC CLEAR LAMINATED SAFTEY GLASS
114	EXECUTIVE PASSAGE	118		2400	2400	6.76 ACOUSTIC CLEAR LAMINATED SAFTEY GLASS
115	EXECUTIVE PASSAGE	118		2400	2400	6.76 ACOUSTIC CLEAR LAMINATED SAFTEY GLASS

IRONMONGERY SET - 12



TYPE SF-3

ELEVATION

DESCRIPTION	TYPE
HB5 NUKLIP PURPOSE MADE POWDER COATED ALUMINIUM SHOPFRONT SYSTEM BY SPECIALIST, HINGED SINGLE DOOR 900mm WIDE x 2400mm HIGH	SF-4

DOOR NO	ROOM DESCRIPTION NAME	NO.	ACTIVE LEAF	HAND	DOOR CONSTRUCTION WIDTH	HEIGHT	GLAZING
35	RECEIVING AREA	036			900	2400	6.38mm CLEAR SAFETY GLASS

IRONMONGERY SET - 26

ACCESS CONTROLLED



TYPE SF-4

ELEVATION

DESCRIPTION	TYPE
HB5 NUKLIP PURPOSE MADE POWDER COATED ALUMINIUM SHOPFRONT SYSTEM BY SPECIALIST, 1500mm WIDE x 2400mm HIGH - HINGED SINGLE DOOR 900mm WIDE x 2400mm HIGH WITH 600mm WIDE SIDE LIGHT	SF-5

DOOR NO	ROOM DESCRIPTION NAME	NO.	HAND	DOOR CONSTRUCTION WIDTH	HEIGHT	GLAZING
107	FINANCE 1	112		1500	2400	6.76 ACOUSTIC CLEAR LAMINATED SAFTEY GLASS
108	FINANCE 2	113		1500	2400	6.76 ACOUSTIC CLEAR LAMINATED SAFTEY GLASS

IRONMONGERY SET - 12



TYPE SF-5

ELEVATION

DESCRIPTION	TYPE
HB5 NUKLIP PURPOSE MADE POWDER COATED ALUMINIUM SHOPFRONT SYSTEM BY SPECIALIST.	SF-6

DOOR NO	ROOM DESCRIPTION NAME	NO.	ACTIVE LEAF	HAND	DOOR CONSTRUCTION WIDTH	HEIGHT	GLAZING
58	GATEHOUSE	GH-01			900	2350	6.38mm CLEAR SAFETY GLASS

IRONMONGERY SET - 12



TYPE SF-6

ELEVATION

DOOR NUMBER	DOOR TYPE	ROOM NUMBER	ROOM NAME	ACTIVE LEAF	HANDING	FIRE RATING	REMARKS
01	SF-1	001	WIND LOBBY				ACCESS CONTROL
02	SF-1	002	RECEPTION				ACCESS CONTROL
03	D-1	002	RECEPTION				ACCESS CONTROL
04	FD-2	002	RECEPTION			2HR	FIRE DOOR WITH ACCESS CONTROL
05	SF-2	004	CIRCULATION				ACCESS CONTROL
06	D-2	007	TEA PREP 1				
07	D-3	008	FHR				
08	D-4	009	ELECTRICAL				
09	D-5	011	CLEANERS ROOM				
10	D-6	012	DISABILITY WC				
11	D-13	013	DUCT 1				DUCT
12	SF-3	014	NETWORK OPERATIONS				
13	FD-5	016	ESCAPE STAIR LOBBY			1HR	PUSH-PAD PANIC DEVICE
14	FD-5	016	ESCAPE STAIR LOBBY			1HR	PUSH-PAD PANIC DEVICE
15	D-15	017	ESCAPE STAIR			N/A	FIRE DOOR WITH ACCESS CONTROL
16	FD-2	019	DATA CENTRE HALL 1			2HR	FIRE DOOR WITH ACCESS CONTROL
17	FD-1	019	DATA CENTRE HALL 1			2HR	FIRE DOOR WITH ACCESS CONTROL
18	FD-2	021	DATA CENTRE HALL 2			2HR	FIRE DOOR WITH ACCESS CONTROL
19	FD-1	021	DATA CENTRE HALL 2			2HR	FIRE DOOR WITH ACCESS CONTROL
20	FD-2	024	DATA CENTRE HALL 3			2HR	FIRE DOOR WITH ACCESS CONTROL
21	FD-1	024	DATA CENTRE HALL 3			2HR	FIRE DOOR WITH ACCESS CONTROL
22	SF-2	026	CORRIDOR LOBBY 1				FIRE DOOR WITH ACCESS CONTROL
23	FD-3	023	SERVICES CORRIDOR 1			2HR	FIRE DOOR WITH ACCESS CONTROL
24	D-15	027	MAINTENANCE STAIR			N/A	FIRE DOOR WITH ACCESS CONTROL
25	FD-3	030	SERVICES CORRIDOR 2			2HR	FIRE DOOR WITH ACCESS CONTROL
26	FD-1	028	DATA CENTRE HALL 4			2HR	FIRE DOOR WITH ACCESS CONTROL
27	FD-2	018	CIRCULATION 1			2HR	FIRE DOOR WITH ACCESS CONTROL
28	FD-1	031	CARRIER HOTEL			2HR	FIRE DOOR WITH ACCESS CONTROL
29	FD-2	018	CIRCULATION 1			2HR	FIRE DOOR WITH ACCESS CONTROL
30	FD-1	033	DATA CENTRE HALL 5			2HR	FIRE DOOR WITH ACCESS CONTROL
31	FD-2	033	DATA CENTRE HALL 5			2HR	FIRE DOOR WITH ACCESS CONTROL
32	SF-2	035	RECIEVING LOBBY				ACCESS CONTROL
33	SF-2	036	RECEIVING AREA				ACCESS CONTROL
34	RS-2	036	RECEIVING AREA				ACCESS CONTROL
35	SF-4	036	RECEIVING AREA				ACCESS CONTROL
36	RS-1	018	CIRCULATION 1				
37	RS-1	036	STORE ROOM 2				
38	RS-1	039	STORE ROOM 1				
39	FD-1	040	MEET-ME ROOM 2			2HR	FIRE DOOR WITH ACCESS CONTROL
40	SF-2	041	STAGING AREA				ACCESS CONTROL
41	FD-1	042	MEET-ME ROOM 1			2HR	FIRE DOOR WITH ACCESS CONTROL
42	D-8	044	MALE WC 3				
43	D-7	045	FEMALE WC 3				
44	D-8	046	WC				
45	D-9	049	GENERATOR RM 2				ACCESS CONTROL
46	D-10	050	UPS ROOM 2				ACCESS CONTROL
47	FD-2	027	MAINTENANCE STAIR			2HR	ACCESS CONTROL
48	D-10	051	LV RM 2				ACCESS CONTROL
49	D-10	052	TX ROOM 2				ACCESS CONTROL
50	D-10	053	MV ROOM 2				ACCESS CONTROL
51	D-10	055	MV ROOM 1				ACCESS CONTROL
52	D-10	056	TX ROOM 1				ACCESS CONTROL
53	D-10	057	LV RM 1				ACCESS CONTROL
54	FD-2	059	FIRE SUPRESSION RM 1			2HR	ACCESS CONTROL
55	D-10	058	UPS ROOM 1				ACCESS CONTROL
56	D-9	060	GENERATOR RM 1				ACCESS CONTROL
57	D-8	GH-02	GATEHOUSE WC				
58	SF-6	GH-01	GATEHOUSE				
59	D-5	024	DATA CENTRE HALL 3				
60	D-5	021	DATA CENTRE HALL 2				
61	D-5	019	DATA CENTRE HALL 1				
62	D-5	028	DATA CENTRE HALL 4				
63	D-5	031	CARRIER HOTEL				
64	D-5	033	DATA CENTRE HALL 5				
65	D-14	018	CIRCULATION 1			N/A	
67	FD-8	124	ABOVE DATA HALL CEILING			2HR	
68	FD-8	124	ABOVE DATA HALL CEILING			2HR	
69	FD-8	124	ABOVE DATA HALL CEILING			2HR	
70	FD-8	125	ABOVE DATA HALL CEILING			2HR	
71	FD-8	125	ABOVE DATA HALL CEILING			2HR	
72	FD-8	125	ABOVE DATA HALL CEILING			2HR	
101	D-8	104	MALE WC 2				
102	D-7	105	FEMALE WC 2				
103	D-3	106	FHR				
104	D-4	107	ELECTRICAL				
105	D-2	108	TEA PREP 2				
106	D-11	110	SERVER RM				ACCESS CONTROL
107	SF-5	112	FINANCE 1				
108	SF-5	113	FINANCE 2				
109	SF-2	115	BALCONY 2				ACCESS CONTROL
110	FD-6	114	ACCOUNTS			1HR	PUSH-PAD PANIC DEVICE
111	SF-3	102	MEETING ROOM 2				
112	SF-2	101	CIRCULATION				ACCESS CONTROL
113	SF-2	116	EXECUTIVE PAUSE AREA				ACCESS CONTROL
114	SF-3	118	EXECUTIVE PASSAGE				
115	SF-3	118	EXECUTIVE PASSAGE				
116	SF-2	118	EXECUTIVE PASSAGE				ACCESS CONTROL
117	D-12	122	BALCONY 1				
118	FD-8	123	SLAB - TOP OF MAINTENANCE STAIR			2HR	FIRE DOOR WITH ACCESS CONTROL
123	FD-8	123	SLAB - TOP OF MAINTENANCE STAIR			2HR	FIRE DOOR WITH ACCESS CONTROL

The design and content of this drawing is the property of
Osmond Lange Architects and the copyright thereof is reserved by them.

No	Date	Revision Description	By
B	16-03-20	DOORS REVISED	PM
A	06-03-20	ISSUED FOR TENDER	PM

Osmond Lange Architects and Planners
Pilot Mill House, The Quarry, Selborne
East London
(043) 721-0033
William Martineon
083329600
Williamm@o-l.co.za

Newground Projects
17 St Andrews Road, Selborne,
East London, 5201
043 722 5864
Louis Fourie
082576682
Louis@newground.co.za

Evans Consulting Engineers cc
17 Surrey Road, Vincent, East London 5247
043 7231192
Daryl Evans
083 7026399
daryl@evansconsulting.co.za

CS Consulting
12 Pearce Street, Harraway House
Berea, East London 5241
Craig Sam
0793287147
Craig@csamconsulting.co.za

BVI Border
1st Floor, Esprit House, St Helena Drive
East London, 5241
043 - 722 2738
Werner de Lange
082 578 0874
WernerdL@bvi.co.za

Bisiwe Van Niekerk
The Ridge Office Park, 2nd Floor
3 Berea Terrace, Berea, East London
043 721 1043
Willem van Niekerk
082482165
willem@bisiwe.co.za

Client

east london idz
business streamlined

Architects

Osmond Lange Architects and Planners (Pty) Ltd East London
Postal: Private Bag X3, Tecoma 5214
Address: Pilot Mill House
The Quarry
Selborne, East London
Tel: (043) 721-0033
Fax: (043) 721-0038
Email: olael@o-l.co.za

Project

PROPOSED DATA CENTRE ON ERF 60917

Drawing Title

DOOR SCHEDULE - SHEET 2

Date	Drawn	PM
05/03/2020	Checked	WM
Scale 1 : 50	Approved	WM

Workstage: FOR TENDER

Drawing Number: E1439-DCX-AR-601

Revision: B

2020/03/17 11:07:26