

ATTENTION: TO ALL TENDERERS

ADDENDUM NO.: 1

PROJECT NO.: ES/20/REFURBISHMENTS/01

PROVISION OF STRUCTURAL DEFECT REPAIRS AND GENERAL REFURBISHMENT TO ELIDZ BUILDINGS

This addendum forms an integral part of the above-mentioned tender. Tender documents shall be amended accordingly before a tender is submitted.

Tenderers are requested to complete and sign the acknowledgement attached to this form, which is to be incorporated in the tender document, closing at 12:00 on the 16th October 2020.

AMENDMENTS:

Please use the attached pages of the Bill of quantities to replace the ones previously issued in the tender document. The revision in this addendum will supersede any previously issued information on the respective item(s) in the Bill of Quantities.

Please NOTE the following listed changes:

SECTION 2: ALTERATIONS AND DEMOLITIONS (PROVISIONAL)

Bill No.1/Item 9: Allow for protection of existing electrical cabling and lighting fittings where required during construction period.

Bill No.1/Item 12: Sand down and clean previously painted floors and walls with flaking/ deteriorated paint in preparation for new paint (elsewhere)

Bill No.2/Item 3: Take out any debris, sand and dust from deteriorated movement joints in concrete hardstanding and reseal with approved polysulphide sealant to manufacturer's specification.

10mm Joints not exceeding 300mm high (Provisional).

Bill No.6/Item 1: Ceramic floor tiles (Allow a PC Sum of R185/m²) fixed with adhesive to screed (elsewhere) and flush pointed with waterproofing grout.

On smooth floors.

Bill No.7/Item 2: Welded balustrading to concrete:

3m long and 1m high handrails with vertical crossbars at 200mm centres.
(50 x 2.5mm diameter hot deep galvanised handrails, 16mm solid steel rods (balustrade) welded to 75 x 75 x 3mm hollow square sections where directed)

Bill No.10/Item 4: Prepare and apply one coat universal primer, one undercoat and two coats 'Plascon Wall 'n All' or similar approved. Paint colour to Engineer's specification.

On plastered walls

Please use the attached pages of the bill of quantities as the one in the tender document has been superseded.

ATTACHMENTS

Revised BOQ.

ADDENDUM NO.: 1

PROJECT NO.: ES/20/REFURBISHMENTS/01

PROVISION OF STRUCTURAL DEFECT REPAIRS AND GENERAL REFURBISHMENT TO ELIDZ BUILDINGS

I/We acknowledge the receipt of Addendum No. 1 that forms part of the Tender Document and I/We have included all the amendments in Tender No.: ES/20/REFURBISHMENTS/01

NAME OF TENDERER:

NAME OF SIGNATORY:

SIGNATURE (ON BEHALF OF TENDERER):

ADDRESS OF TENDERER:

.....

.....

CONTACT DETAILS OF TENDERER:

Tel:

Fax:

DATE:

Please ensure that the contents thereof are noted and included in your tender submission. Should you have any queries please do not hesitate to contact Anathi Mgwaza on email to anathi@elidz.co.za