



#### GENERAL NOTES TO CONTRACTOR

- 1.) Door frame profiles are manufactured according to SABS specification No. 1129 of 1977
- 2.) Always check the frames when building for squareness and plumb as they cannot be corrected afterwards
- 3.) After building in the contractor is to take all necessary measures to protect the frames from any on-site damage.

Two hour fire rated double door		Type: 1613 x 2125mm	Quantity: 01	Type Mark: D02
<b>Door</b> <b>Description:</b> iFUBA 40mm thick Trucore Pyrocoust, 28dB Class A 2 hour minute fire door, manufactured in accordance with SANS 1253:2004, size 1525 x 2032mm high with veneer finish. (door ironmongery elsewhere specified) and galvanised & powder coated steel frame suitable for (wall thickness) brick wall, installed in accordance with the manufacturer's instructions.  <b>Finish:</b> <b>Description:</b> As per approved manufacturer	<b>Frame</b> <b>Description:</b>          <b>Finish:</b> <b>Description:</b> As per approved manufacturer			
<b>Ironmongery:</b> Refer to Ironmongery Schedule	<b>Glazing:</b> None			
QUANTITIES TO BE VERIFIED PRIOR TO PLACEMENT OF ORDER. MASONRY OPENINGS TO BE VERIFIED ON SITE PRIOR TO COMMENCEMENT OF MANUFACTURE. SUPPLIER TO BE IN ACCORDANCE WITH ALL SABS AND NBR STANDARDS				