



Legend / Quantities					
Item	Type	Unit	Warehouse Countdown	GF Office	FF Office
CABLE	8mm² 4 AC Cu CONDUCTOR, (FACTORY FLOOR, EMERGENCY & EXTERIOR LIGHTING)	m			900
	SSO For Warehouse lights, 5A, unswitched		493		493
	LIGHT SWITCH		1	15	3
	32W Recessed BEKA LED Panel, 600x600, 4000K, 3m Cable with 6A SSO		0	11	25
	32W Recessed BEKA LED Panel, 600x600, 4000K, 3m Cable with 6A SSO, Emergency		0	16	10
	BEKA LEDBAY Mid 192 LED 150W with 4010 Optic, 4000K, including U Bracket and 3m Cable with 6A SSO		365	0	0
	BEKA LEDBAY Mid 192 LED 150W with 4010 Optic, 4000K, including U Bracket and 3m Cable with 6A SSO		91	0	0
	ULSAVPS35W/ND15000, LED Lighting 5A Luminaire, 4000K, including mounting bracket, Vapourproof, 3m Cable with 6A SSO		39	2	0
	BEKA LEDNOVA Mini 34W Series 10 LED with S304 Optic, 4000K, including SS Stripup, 3m Cable with 6A SSO		40	0	0
	BEKA 11W Series 41 LED ND, Black bulkhead, 4000K		0	0	0
	BEKA 11W Series 41 Emergency LED ND, Black bulkhead, 4000K		8	1	0
	PHOTO CELL		1		1
	GOSINEXT2W/IRM Emergency Route Luminaire, 3m Cable with 6A SSO		8	2	0
	ULSAOLD16W/ND170White LED Lighting 5A Luminaire, 4000K, including mounting bracket, 3m Cable with 6A SSO		0	15	5
	ULSAOLD16W/ND170White LED Lighting 5A Luminaire, 4000K, including mounting bracket, 3m Cable with 6A SSO		0	18	0
	Occupancy Sensor		0	13	4
	P5000 76x127mm TRAY + LID		3600		3600
	P2000 76x76mm TRAY + LID		240		240

GENERAL NOTE
The design and content of this drawing is the property of KCS and shall remain the property of KCS. It is not to be used for any other purpose without the written consent of KCS. The design and content of this drawing is the property of KCS and shall remain the property of KCS. It is not to be used for any other purpose without the written consent of KCS.

PROJECT TEAM
Project Managers:
KCS
Architects:
ENM
Quantity Surveyors:
LATITUDE
Civil Engineers:
gvi
Structural Engineers:
RUTAR
Electrical & Mechanical Engineers:
KCE

CLIENT
east london idz
CLIENT APPROVAL:
DATE:

TENANT
NAME: _____ TENANT APPROVAL: _____
SIGNATURE: _____ DATE: _____

Project: OE/001/2022 DTSA

Drawing Title: Sequencing Facility Lighting

Date: 10/10/2024 Drawn: B.M.E.
Scale: 1:200 Checked: D.P.

Approved:
Name: _____ Reg No.: _____
Signature: _____ Date: _____
Practico: _____

Workstage: For Tender Purposes
Drawing Number: 3244-ELEC-02
Revision: 0