



2	RECORD DRAWING	PAS	30/03/2012
5	GENERAL AMENDMENTS	PAS	08-2011
4	ADDITION SECTION G-G AND H-H AND OPENINGS ON SECTION PLAN D-D BEAM POSITIONS ON PIGGING PLATFORM	PAS	06-2011
3	SECTION PLAN D-D AMENDED PARTIAL ELEVATION ADDED COLUMN ADDED TO SECTION E-E	PAS	05-2011
2	GENERAL AMENDMENTS	PAS	02-2011
1	ISSUED FOR CONSTRUCTION	PAS	11-2010
0	ISSUED FOR TENDER PURPOSES	PAS	02-2010
No	AMENDMENTS	APPR.	DATE
GENERAL NOTES:			
1. ALL CONCRETE IN FLOOR, WALLS, SLABS AND ROOF, TO BE 40Mpa/19mm WITH MINIMUM CEMENT CONTENT OF 325kg/m ³ .			
2. CONCRETE COVER TO REINFORCEMENT TO BE 60mm.			
3. NO CONCRETE TO BE POURED UNTIL THE STEEL HAS BEEN INSPECTED BY THE CONSULTING ENGINEER.			
4. ANY BREAKS IN THE CONCRETE ARE TO BE MADE IN ACCORDANCE WITH THE ENGINEERS INSTRUCTIONS.			
5. NO STRUCTURAL ALTERATIONS TO BE MADE WITHOUT THE APPROVAL OF THE CONSULTING ENGINEER.			
6. ALL DIMENSIONS TO BE CHECKED ON SITE BEFORE WORK IS PUT IN HAND. ANY DISCREPANCY MUST IMMEDIATELY BE REPORTED TO THE ENGINEER.			
7. THIS DRAWING IS NOT TO BE SCALED.			
8. REFER TO 1359/PSN312 FOR LADDERS			
9. REFER TO 1359/PSN316 FOR CONCRETE STAIRS			
SURVEYED	FILE	SURVEY CHECKED	
DESIGNED	CC	DRAWING CHECKED	PAS
DESIGNED	PAS	DESIGN CHECKED	
PLOT FILE		PLOT SCALE	
PROJECT CONTROLLER			
PROJECT DIRECTOR			
CLIENT/EXTERNAL APPROVAL:			
FOR:			
DATE:			
CONSULTING ENGINEER:			
CLIENT:			
PROPOSED MARICULTURE DEVELOPMENT IN ZONE 1A			
CONTRACT 3: CONSTRUCTION OF SALT WATER EXTRACTION WORKS AND PUMP STATION			
PUMP STATION CONCRETE LAYOUTS			
SCALE	SHEET 1 OF 1 SHEETS	DATE	
AS SHOWN		AUGUST 2011	
DRAWING No	REVISION		
1359/PSN/311	Z		