



PIPING NOTES

1. FIRE PROTECTION PIPING SUPPLY MAIN TO BE 2500 SCH 40, GALVANISED
2. FIRE PROTECTION PIPING IN (EARTHEN) TRENCHES TO BE AS FOLLOWS:
 - Type Class 16
 - Fully Galvanized, including flanges, nuts, bolts and washers
 - Complete pipework installation, to be degreased using Placon - GR1 - Aqualox - Degreaser of approved supplier equivalent for Wrapoid Bond application
 - Putty sealant and all flange connections, including bolt cluster for sealed Wrapoid Bond installation
 - Wrapoid Bond complete underground pipe installation, to Canusa-CPS specification
3. ALL FIRE PROTECTION PIPING AND INSTALLATION THERE TO COMPLY WITH NATIONAL RELEVANT REGULATIONS

