

PLAN VIEW SHOWING KEY FLOOR PAINT LOCATIONS

SCALE 1:200

PAINT APPLICATION METHODOLOGY

- *Prepare by diamond grinding the floor.*
- *Acetone wipe upon completion.*
- *Apply one coat of Sigmacover 456 twin pack epoxy primer.*
- *Mask up and apply two coats of Sigmadur 550 twin pack epoxy in yellow and black.*
- *Remove masking tape and allow to cure.*

PAINTING NOTES

1. Refer to painting methodology outlined below
2. The sizes are to be agreed on site, and determined by adding 150mm on each side of the equipment/apparatuses /door the chevron is serving, and a minimum of 1000 mm dimp.
3. Where two chevrons overlap or are in close proximity, they should be combined into a single painted chevron.

The design and content of this drawing is the property of BNM Architects and it's copyright thereof is reserved by them.

GENERAL NOTE

1. ALL STRUCTURAL, ELECTRICAL, CIVIL AND LANDSCAPING QUERIES ARE TO BE REFERRED TO THE RELEVANT CONSULTANTS DRAWINGS, SPECIFICATIONS AND DETAILS.
2. ALL PLUMBING QUERIES ARE TO BE REFERRED TO THE RELEVANT SPECIALIST CONSULTANTS DRAWINGS, SPECIFICATIONS AND DETAILS
3. ALL BRICKWORK AND BLOCKWORK TO BE CONSTRUCTED AS REFERRED TO PR. STRUCTURAL ENGINEER'S DRAWINGS, SPECIFICATIONS AND DETAILS.
4. ALL BRICKWORK / INTERNAL WALLS REQUIRING BRACING / STIFFENING ARE TO BE CONSTRUCTED IN ACCORDANCE WITH PR. STRUCTURAL ENGINEER'S DRAWINGS, SPECIFICATIONS AND DETAILS
5. ALL ROOF CONSTRUCTIONS AND ROOF PENETRATIONS TO BE REFERRED TO CONSULTANTS DRAWINGS, SPECIFICATIONS AND DETAILS.
6. ALL DESIGN AND CONSTRUCTION TO COMPLY WITH THE RELEVANT SANS CODES OF PRACTICE
7. ANY DISCREPANCY IN THE DRAWINGS, DIMENSIONS & SPECIFICATIONS TO BE REPORTED TO THE ARCHITECT BEFORE PROCEEDING WITH ANY WORK AND CLARIFIED BY THE ARCHITECT PRIOR TO ANY WORK BEING PUT IN HAND.
8. ONLY FIGURED DIMENSIONS TO BE FOLLOWED - SCALED DIMENSIONS OF DRAWINGS WILL NOT BE PERMITTED

No	Date	Revision Description	By

TYPICAL PAINTING ARRANGEMENTS



PROJECT TEAM

Project Managers :

KCS Consultants
1 Malta Street, Glendinningvale, East London, 5241
Cell: 073 6135
Keith Simon
073 613 5135
keithsim@kcs.co.za

Architects :

BNM Architects
Suite 1 Lyndon, 114 Park Drive, Vincent, East London
041 583 2125
079 648 9980
ndlovu@bnm.co.za

Quantity Surveyors :

Latitude Quantity Surveyors
122 Western Avenue
Vincent
East London
Petra Walker
082 929 0675
pwalker@latitudeqs.co.za

Civil Engineers :

BVI Consulting Engineers
Unit 1, 1 Fleet Street, Berea Road
Beacon Bay, East London
043 723 3739
Warren Taylor
082 578 0474
WarrenT@bvi.co.za

Structural Engineers :

Zutari Consulting Engineers
1 Fleet Street, Berea
East London
043 726 9000
Kate Rockledge
078 2514867
eastlondon@zutari.com

Electrical & Mechanical Engineers :

Kcetekuhuma Consulting Engineers
30 East Bank Road, Beacon Bay
East London
043 748 6700
Dean Pretorius
082 464 9730
dean@kcemep.co.za

CLIENT

PO Box 5458, Greenfields
East London, 5206

Lower Chester Road
Sunnyridge, 5201
East London, South Africa

Tel: +27(0)437039200
Fax: +27(0)4373664635
Email: info@eelidz.co.za

CLIENT APPROVAL :

DATE :

Gary Whittaker
Project Manager
Tel: 043 7025247
Cell: 082 3463299
E-mail: garyw@eelidz.co.za

TENANT

NAME :

TENANT APPROVAL :

DESIGNATION:

DATE :

Project
EB/NW1/10/24/Z1A

Drawing Title
Fire protection services
Warning paint layout

Date	10/10/2024	Drawn	B.M.E.
Scale	1 : 200	Checked	D.P.

Approved

Name: - Reg No: -

Signature: Date:

Practice:

Workstage
For Tender Purposes

Drawing Number	Revision
3244-FP-10	0

23 May 2025 09:15:26